



The South African Pipeline Gas Association  
Postnet Suite 141  
Private Bag X04  
Fontainebleau  
2032

Tel: +27 (0) 11 431 2016  
Fax: +27 (0) 86 525 3415

# PRESSURE TEST CERTIFICATE INDUSTRIAL

Company name: \_\_\_\_\_

Address: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Distribution area: \_\_\_\_\_

Contact Person: \_\_\_\_\_ Tel. no: \_\_\_\_\_

---

## 1. INTERNAL PIPELINE INSTALLATION

Name (in block letters): \_\_\_\_\_ Designation: \_\_\_\_\_

For and on behalf of (Company): \_\_\_\_\_

Address: \_\_\_\_\_  
\_\_\_\_\_

Signature: \_\_\_\_\_ Tel No.: \_\_\_\_\_

Pipe material: \_\_\_\_\_ Schedule: \_\_\_\_\_

(Full description of pipe work installed: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



**2. PRESSURE TESTING PERFORMED BY:**

Name (in block letters): \_\_\_\_\_ Designation: \_\_\_\_\_

For and on behalf of (Company): \_\_\_\_\_

Address: \_\_\_\_\_

Signature: \_\_\_\_\_ Tel No.: \_\_\_\_\_

Pressure test medium:  Air  Nitrogen (inert gas)  Water

$P_{test} = 700 \text{ kPa}$  ; duration = 24 hrs (with a  $P_{supply} < 625 \text{ kPa}$ )

$P_{test} = 900 \text{ kPa}$  ; duration = 24 hrs (with a  $P_{supply} > 625 \text{ kPa}$ )

Design pressure: \_\_\_\_\_ kPa Test pressure: \_\_\_\_\_ kPa

Test duration: \_\_\_\_\_ hrs Gauge range: \_\_\_\_\_ kPa

Gauge last calibrated on (Date): \_\_\_\_\_

Comment: \_\_\_\_\_

With regards to the pressure test done on \_\_\_\_\_ (date), the internal gas pipeline was under pressure at \_\_\_\_\_ kPa / bar for \_\_\_\_\_ hours.

I certify that, no pressure drop occurred and no leaks were evident.

\_\_\_\_\_  
NAME

\_\_\_\_\_  
SIGNED

Practitioner SAQCC No \_\_\_\_\_